

Certificate of Compliance

Certificate Number:

EX29457

Report Reference:

EX29457-2024-10-25

Issue Date:

2025-MAR-14

Issued to:

PIPE STEEL INDUSTRIES

**Kwai Shing Industrial Building Phase 1, 36-40 Tai Lin Pai Road,
Kwai Chung, N.T.**

This certificate confirms that representative samples of:

VIZY - Metallic Sprinkler Pipe

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 852, Edition 2, Issue Date 2008-10-01, Revision Date 2023-03-07

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number EX29457
Report reference EX29457-2024-10-25
Date 2025-MAR-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Metallic Sprinkler Pipe

Steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with threaded or unthreaded ends intended to be joined by threading, welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 40 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, and 12 in. sizes, per ASTM A53, Type S or Type E, Grade B

Schedule STD steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, and 12 in. sizes, per ASTM A53, Type S or Type E, Grade B

Schedule 80 steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, and 12 in. sizes, per ASTM A53, Type S, Grade B



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.